



TYPE OF CONNECTIONS WHICH CAN BE USED ON PIPE SQUARE AND RECTANGULAR TUBING UP TO FOUR CONNECTIONS AT ONE ELEVATION.

FIREPROOF COLUMN DETAILS

THESE DETAILS ARE TO BE USED ONLY AS A GUIDE FOR CONSTRUCTION. THE EXACT SHELL LENGTHS AND POSITION ARE REQUIRED TO MAINTAIN FIRE RATING OF COLUMNS AND TO PREVENT INTERFERENCE DURING ERECTION.

GENERAL NOTES: CONNECTIONS ON THE FACE ARE ALLOWED FOR MISCELLANEOUS USES, PROVIDED THE CONNECTIONS DO NOT INTERFERE WITH THE CONSTRUCTION AND ARE NOT SUBJECT TO STRESSING.

SIGNED CAD-DRAWING APPROVALS WILL APPEAR ONLY ON ORIGINAL ISSUE.

TOL. NOT SPECTD: .XXX ±.005 .XX ±.010 .X ±.015

SCALE: N/A ANGLES ±2'

DATE: 06.02.09

DR: [Blank]

APP: [Blank]

REV: [Blank]

REV.	CHANGE	DATE	BY	CHK
B	UPRATED TO 8000 AND 1000'S	05.07.06	TAF	

THIS IS A CAD GENERATED DRAWING. CHANGES MUST BE MADE ON CAD SYSTEM.

REL. FOR PRODUCTION

REL. FOR T. D. & P.

FIRE-TROL, EXAMPLE

420 Woodland Road
 Tel: 610.394.8142
 Fax: 610.394.8144
 2008 DAILY, L.P.

REV. SHEET: 1 B

OF: 1